




TD5.AUX3-BT
220V - 1Ø - 60 Hz
SALA DE DERIVACIÓN MT

VIENE DE S.E.05 — 6 mm² NHX-90
(35 mm) Ø PVC-P

6 mm ² NHX-90	I.G. 2x32 A INTERRUPTOR GENERAL	C2 2x20 A TOMACORRIENTE DE SALA DE DERIVACION MT	4 mm ² NHX-90
4 mm ² NHX-90	C-1 2x16 A ALUMBRADO DE SALA DE DERIVACION MT	C2-3 RESERVA 1	



MANDIL (1 HOJA - BISAGRAS A LA DERECHA)
ALIMENTADOR PRINCIPAL: INGRESA POR ARRIBA
ALIMENTADOR 1 TERNA 6 mm² NH-90

T.D.03

DIAGRAMA UNIFILAR DEL TABLERO DE DISTRIBUCION ELECTRICA:TD03

